

NOTES:

- 1. HYDRANTS TO BE SET WITH BURY LINE POSITIONED AT GRADE WITH NOZZLES AT MIN. OF 16 INCHES ABOVE GROUND.
- 2. WHEN SET BEHIND CURB THE NOZZLES ARE TO BE PARALLEL OR AT RIGHT ANGLES TO THE CURB, WITH THE PUMPER NOZZLE FACING THE CURB. THE PUMPER NOZZLE WILL BE A MIN. DISTANCE OF 16 INCHES FROM THE FACE OF THE CURB.
- 3. HYDRANT MUST HAVE SAFETY BREAKAWAY FEATURE SUCH AS MUELLER CENTURIAN 250 A421 OR APPROVED EQUAL.
- 4. 6" DUCTILE IRON CLASS 350 FROM TEE TO HYDRANT. VALVE TO BE RODDED TO TEE. VALVE & HYDRANT TO HAVE MEGALUGS.
- 5. COARSE GRAVEL OR CRUSHED STONE IS TO BE PLACED FROM THE BOTTOM OF THE TRENCH TO AT LEAST 6 INCHES ABOVE THE DRAIN OPENINGS IN THE HYDRANT AND AT A DISTANCE OF ONE FOOT AROUND THE ELBOW.

	CITY OF NORFOLK — DEPARTMENT OF UTILITIES STANDARD DETAILS	SCALE: NOT TO SCALE
DATE: 11/05	FIRE HYDRANT INSTALLATION DETAIL	DRAWING NO.